



Rosa Power Supply  
Company Limited  
CIN: U3110MH1994PLC243148

Administrative Block, Hardoi Road,  
P.O. Rausar Kothi, Tehsil-Sadar,  
District – Shahjahanpur  
Uttar Pradesh 242 406

Tel: +91 05842 306600  
Fax: +91 05842 300003  
www.reliancepower.co.in

Ref: RPSCL/ENV/STATEMENT/04/2024/06

Date: 23.04.2024

To,  
The Member Secretary  
Uttar Pradesh Pollution Control Board  
TC 12 B- Vibhuti Khand  
Gomati Nagar, Lucknow

**Sub: Submission of Environment Statement (FORM V) of FY 2023-24 for Stage I & II**

Dear Sir,

This is with reference to the Air & Water (Both) CCA (Consolidated Consent & authorization) (Fresh) under Section-25 of the Water (Prevention & Control of Pollution) Act, 1974 and under Section-21 of the Air (Prevention & Control of Pollution) Act, 1981 **Ref No- 192619/UPPCB/Bareilly(UPPCBRO)/CTO/both/SHAHJAHANPUR/2023 Dated:02.02.2024** and **Application No- 22729975 Dated:18.09.2023** for Stage-I, issued to us. CCA (Consolidated Consent & authorization) is valid till 31<sup>st</sup> December 2028 and **Ref No- 192998/UPPCB/Bareilly (UPPCBRO)/CTO/both/SHAHJAHANPUR/2023 Dated: 02.02.2024** and **Application No- 22797427 Dated: 18.09.2023** for Stage-II, issued to us. CCA (Consolidated Consent & authorization) is valid till 31<sup>st</sup> December 2028 issued to us and Environmental Clearance **J-13011/19/2005-IA.II(T) dated 14.03.2006** for Stage I & Environmental Clearance **J-13011/73/2007-IA.II(T) dated 20.07.2009** for stage II.

As advised, please find enclosed the Environmental Statement for the Stage I & II of the FY 2023-2024 both in soft as well as hard copy.


Thanking You,

*For Rosa Power Supply Co. Ltd.*

  
(Authorized Signatory)



Cc: (I) Regional Officer UPPCB Bareilly  
(II) Regional Officer MoEF Lucknow



# ENVIRONMENTAL STATEMENT

OF

Rosa Power Supply Company Ltd.  
Shahjahanpur (U.P.)

2 x 300 MW (STAGE-I)

FINANCIAL YEAR ENDING THE 31<sup>st</sup> MARCH, 2024

Prepared by:

Rosa Power Supply Company Ltd.  
Shahjahanpur (U.P.)



**(FORM – V)**  
**(See Rule 14)**

Environmental Statement Report for the Financial Year ending 31st March, 2024.

**PART – A**

- (i) Name and address of the : Mr. H S Tomar  
Owner/occupier of the Industry Rosa Power Supply Co. Ltd.  
operation or process P.O.-Rausar Kothi  
Hardoi Road  
Distt. – Shahjahanpur(U.P.)
- (ii) Production Capacity : 2X300 MW
- (iii) Year of Establishment : March 2010
- (iv) Date of Last environmental statement : 06.05.2023  
submitted
- (v) Industry category : Thermal Power Plant Coal Based  
Primary : (STC Code)  
Secondary : (SIC Code)



## PART – B

### (Water and Raw Material Consumption)

#### 1. Water Drawn M<sup>3</sup>/Day

(All values indicate Annual consumption)

			FY 2022-23	FY 2023-24	Remarks
(I)	Gross Energy Generation (MU)	:	3909.08	3924.40	Unit Generation is more than previous year.
(ii)	Water consumption	:	9953007 M <sup>3</sup>	10810199 M <sup>3</sup>	Total Water Consumption is more due to more generation than previous year.
(iii)	Process	:	2149849 M <sup>3</sup>	2335003 M <sup>3</sup>	-do-
(iv)	Condenser Cooling	:	7774293 M <sup>3</sup>	8443846 M <sup>3</sup>	-do-
(v)	Domestic	:	28863 M <sup>3</sup>	31350 M <sup>3</sup>	-do-

S.No.	Name of the product	Process water Consumption per unit of product output.	
		FY 2022-23	FY 2023-24
1	Electricity	0.55 Ltr/ Unit*	0.59 Ltr/ Unit*

\*The specific process water consumption was more due to more PLF in summer season.

#### 2. Raw Material Consumption

Name of Raw Material	Name of the product	Consumption of Raw Material unit of output			
		FY 2022-23		FY 2023-24	
Coal	Electricity	Total Consumption (MT)	2420465	Total Consumption (MT)	2434516
		Specific Consumption per kw	0.62	Specific Consumption per kw	0.62

\*The Specific Coal consumption is similar as compared to previous year due to efficient Operation.



## PART – C

**Pollution discharged to Environment/Unit of output**  
(Parameter as specified in the consent issued)

Pollutants	Quantity of Pollutions discharged (mass/day) Kg/day	Concentration of Pollutants in discharge (mass/volume) Kg/m <sup>3</sup>	Percentage of variation from prescribed Standards
<b>Treated Effluent Discharge*</b>			
Unit                      Limit			% below –
pH                      5.5. to 9.0	-----	-----	70%
SS                      < 100 mg/l	0.02	0.028	95%
Oil & Grease      < 10 mg/l	0.00	0.000	86.7%
BOD <sub>3 day</sub> < 30 mg/l	0.00	0.007	82.4%
COD                      < 250 mg/l	0.02	0.038	
<b>Air**</b>			
SPM-Unit 1	1860.18	47.50	
SPM- Unit 2	1811.33	47.34	
	Kg/ day	mg/Nm <sup>3</sup>	

\*-Above data taken from test report of MoEF approved Laboratory for the sample taken on 30.03.2024 and average treated effluent flow is 0.30 CuM/day. (Refer Annexure\_1.)

\*\* - As per Test Report of MoEF approved Laboratory dated 05.03.2024 of Unit 1 & dated 12.03.2024 of Unit 2 of Stage\_1 respectively (Enclosed as Annexure\_2)



PART – D

HAZARDOUS WASTES

(As specified under Hazardous wastes/management  
& Handling Rules, 1989)

Hazardous Wastes	Total Qty (KG)	
	FY 2022-23	FY 2023-24
(a) From Process	10.93 KL (Spent oil) 178.00 kg (Waste containing oil)	38.58 KL (Spent oil) 4734.22 kg (Waste containing oil)
(b) From Pollution Control facilities	2.19 KL	7.72 KL

The RPSCL has obtained Hazardous Waste Authorization from UPPCB for Collection & Storage of Hazardous waste.

Waste/ Spent Oil is collected at centrally located point in isolated stores area meant for them in sealed drums, which is further sent to authorized recycler for disposal as per norms of MoEF.



PART – E

SOLID WASTES

Total Quantity

Solid Wastes:

Solid Wastes:	Total Qty (Metric tonne or MT)	
	FY 2022-23	FY 2023-24
(i) From Process	177329 MT ( Bottom Ash)	175506 MT ( Bottom Ash)
(ii) From Pollution Control Facilities		
• Ash	• 709320 MT	• 702025 MT
• STP Sludge	• 20.82 MT	• 21.14 MT
c)		
I. Quantity recycled or re-utilized within unit	I. 202	IV. 31983.83
II. Sold* (Fly Ash)	II. 543515 -----	V. 00 -----
III. Disposed (Bottom Ash)	III. 274496 -----	VI. 00 -----

❖ \*The ash is given to various agencies free of cost.



## PART – F

### Indicate disposal practice adopted for Hazardous as well as solid waste

- a) **Coal Ash:** As per MoEF guidelines, ash is being given to outside brick unit other than brick kiln; various cement industries for using ash as ingredients in their cement manufacturing units from our silo in closed trucks. Pond ash is lifted for Ash Pond dyke bund rising.
- b) **Used Batteries:** Collected centrally at store in isolated place for disposal to authorized agencies as per MoEF guidelines.
- c) **Hazardous waste:** Waste oil, Oil soaked cotton is collected in store for disposal to authorized agencies as per latest guidelines of MoEF.
- d) **E-Waste-** E-Waste is collected in store for disposal to authorized agencies as per latest guideline of MoEF.
- e) **Bio-Medical Waste-** Bio-medical waste is picked up by authorized agencies on daily basis from health centre.





## PART – G

*Impact of the pollution control measures taken on conservation of natural resources and consequently on the cost of production.*

Pollution Control facilities such as ETP/ STP help in conservation of water resources. The treated water from ETP & STP is used for Ash Handling & Horticulture. Also, the plant is operated on a CoC of more than 5 as against the designed CoC of more than 4 which is helping in further water conservation. All these measures effectively reduce the fresh water intake.



## PART – H

### **Additional investment proposal for environmental protection abatement of pollution, prevention of pollution**

1. Tree Plantation is being carried out in and around the plant premises. Total 16550 nos. of trees and shrubs have been planted in the FY 2023-24 (common for stage 1 & 2). Total 601752 trees has been planted so far in area of 283 Ha i.e approx 46% against 33% greenbelt of MoEF Guideline.
2. During Financial year 2023-24 total expenditure of Rs 1.5 Cr approximately done on horticulture & greenery development (common for stage 1 & 2).
3. Company has successfully passed the surveillance Audit for the Environment Management System Certification (ISO 14001:2015).
4. Continuous Air Quality Monitoring Stations (CAAQMS) have been installed in FY 2013-14, Continuous Effluent Monitoring System (CEMS) have been installed in FY 2014-15, and Connected data of Stack Emission, Effluent with CPCB Server in FY 2015-16, Online Coal Ash Analyser in FY 2017-18, Remote Calibration Facility in FY 2019-20 of CEMS, Modification of STP CHP in FY 2020-21, Modification of STP Switchyard (Plant site) in FY 2023-24 with an approximate investment of Rs 1.5 crore, 13 Lacs, 5 Lacs, 34 Lacs, 23.50 Lacs and 18 Lacs approximately respectively. One CAAQMS station with online weather station has been upgraded with E series costing approx 45 lacs.



## PART – I

### Any other particulars for improving the quality of environment.

- (1) We are complying with all the directions and conditions of state and central pollution boards and regular Water & Air consents are in force.
- (2) Regular monitoring of Noise level, AAQ, Waste and Stack Gases is being done. Waste water treatment and recycling is in practice.
- (3) Almost 16550 Tree and shrubs Plantation has been done in the year 2023-24 for improving the quality of environment (commonly for Stage 1 & 2).
- (4) Water conservation by Ash water recirculation.
- (5) To further improve the treated water quality at plant STP, Dual Media Filter has been provided.
- (6) Tree plantation, Prabhat Pheri and Quiz programmes organized on World Environment Day-2023 to increase environmental awareness among employees (Photographs enclosed as Annexure\_3)
- (7) Training to employees from different departments has been given on Environmental Management System (ISO 14001:2015) and environmental aspect impact assessment
- (8) Good Practices/ Environmental Improvement Plans were made to achieve continual Improvement of Environment.

Note: Environmental Monitoring reports of AAQ, Noise, STP, and ETP are enclosed as Annexure 4, 5, 6 & Refer Annexure 1 respectively.

### Following Environmental Improvement Plans were done during the FY 2023-24

- (1) Waste Disposal - Different color coding of drums for Oily waste and General Waste, Segregation of E-waste, Electrical waste
- (2) PCC of the oil storage shed at maintenance yard of all contractors' area
- (3) Agreement for Biomedical waste disposal with approved agency and renewal of Bio Medical Waste Authorization
- (4) Remote Calibration facility with CPCB server upgraded for online Stack Emission Data as per CPCB Guideline.
- (5) Re-utilising the treated effluent from Coal Settling Pit for dust suppression in CHP Area
- (6) Interconnecting sewage water of admin building and fire station with STP for optimum utilization of Sewage Treatment Plant. Also new STP of 10 KLD installed at CHP area to treat sewage water.



# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12780

Annexure - 01

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	31/03/2024
Nature of Sample	:	Effluent Water Sample	Qty of Sample	:	1.0Ltr
Lab. Ref. No.	:	AERL/300324WW0001	Sample Bottle	:	1 Ltr Jerry can
Dispatch No.	:	0020	Sample Description	:	ETP Outlet
Sample Collected by	:	Sampling Staff	D/o Sample Taken	:	30/03/2024
D/o Sample Analysis	:	31/03/2024	D/o of Completion Analysis	:	05/04/2024

## TEST RESULT

S. No.	PARAMETER	UNIT	PROTOCOL	RESULTS	Standard (CPCB) (max)	
					Inlands Surface Water	Public Sewer
1	pH	.....	APHA 4500 H+B	7.64	6.5 - 8.5	6.5 - 8.5
2	Total Suspended Solids(TSS)	Mg/l	APHA 4500 H+B	28	100	600
3	Bio-Chemical Oxygen Demand (3days at 27°C)(BOD)	Mg/l	APHA 4500 (D)	7	30	350
4	Chemical Oxygen Demand (COD)	Mg/l	APHA 4500 (B)	38	250	NS
5	Oil & Grease (O&G)	Mg/l	APHA 4500 (B)	BDL	10	20
6	Total Coliform	MPN/100 ml	IS 15185-2016 RA 2019	Absent	-	-
7	Feecal Coliform	MPN/100 ml	IS 15185-2016 RA 2019	Absent	1000	-

(Authorized Signatory)



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aetlgwalior@gmail.com aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



Annexure- 02

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05.04.2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	01.03.2024 to 31.03.2024
Location	:	Stack Monitoring	Monitoring Conducted by	:	Sampling Staff
Source of Monitoring	:	Boiler Stack -1 (Bi-Flue) of Stage - 1	Environmental Conditions during Sampling	:	Sunny
Lab. Ref. No.	:		Material of Construction	:	MS
Dispatch No.	:		Height From Ground Level	:	65 M

	<b>Boiler Stack – 1</b>
Stack Area / Shape	05M/ Circular
Capacity	1025 TPH
Type of Fuel Used/Consumption per day	Coal/ 190tph
Thimble No.	March-01, March-05, March-09, March-13
Stack Height (M)	275

## TEST RESULT

S.No.	Parameter	Unit	Monitoring Date				Protocol/Method Followed
			05.03.2024	12.03.2024	19.03.2024	26.03.2024	
1.	Temperature	°C	128.00	125.00	127.00	130.00	
2.	Velocity	m/s	31.25	30.83	32.67	31.25	
3.	Sulphur dioxides (SO <sub>2</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	1144.00	1125.33	1146.67	1104.00	IS:11255(Pt-2)2005 (Reaffirmed – 2009)
	Sulphur dioxides (SO <sub>2</sub> ) with 6% O <sub>2</sub> correction		1131.55	929.77	1073.99	926.95	
4.	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	382.86	339.52	375.63	310.62	IS:11255(Pt-2)2005 (Reaffirmed – 2012)
	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) with 6% O <sub>2</sub> correction		378.69	280.51	351.83	260.81	
5.	Particulate matter (PM)	(mg/Nm <sup>3</sup> )	47.50	46.60	47.19	48.54	IS:11255(Pt-I)1985 (Reaffirmed – 2003)

Authorized Signatory





CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aetgwalior@gmail.com aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



TC-12780

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05.04.2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	01.03.2024 to 31.03.2024
Location	:	Stack Monitoring	Monitoring Conducted by	:	Sampling Staff
Source of Monitoring	:	Boiler Stack -2 (Bi-Flue) of Stage - 1	Environmental Conditions during Sampling	:	Sunny
Lab. Ref. No.	:		Material of Construction	:	MS
Dispatch No.	:		Height From Ground Level	:	65 M

	<b>Boiler Stack - 2</b>
Stack Area / Shape	05M/ Circular
Capacity	1025 TPH
Type of Fuel Used/Consumption per day	Coal/ 190tph
Thimble No.	March-02, March-06 March-10 March-14
Stack Height (M)	275

## TEST RESULT

S.No.	Parameter	Unit	Monitoring Date				Protocol/Method Followed
			05.03.2024	12.03.2024	19.03.2024	26.03.2024	
1.	Temperature	°C	129.00	126.00	130.00	128.00	
2.	Velocity	m/s	29.03	30.37	29.61	30.08	
3.	Sulphur dioxides (SO <sub>2</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	1173.33	1136.00	1162.67	1168.00	IS:11255(Pt-2)2005 (Reaffirmed – 2009)
	Sulphur dioxides (SO <sub>2</sub> ) with 6% O <sub>2</sub> correction		1110.76	962.44	951.97	941.94	
4.	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	332.29	325.07	317.84	296.17	IS:11255(Pt-2)2005 (Reaffirmed – 2012)
	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) with 6% O <sub>2</sub> correction		314.57	275.40	260.24	238.85	
5.	Particulate matter (PM)	(mg/Nm <sup>3</sup> )	46.06	47.34	48.66	46.55	IS:11255(Pt-I)1985 (Reaffirmed – 2003)

Authorized Signatory



**WORLD  
ENVIRONMENT  
DAY**

**RELIANCE**

# **World Environment Day 2023**

## **#BeatPlasticPollution**

RELIANCE

A	Programme (5 <sup>th</sup> June 2023)	Timing
1	Prabhat Pheri at Township	05.30AM
2	Tree Plantation (CHP Area)	9:45 AM
3	Online Quiz Competition for employee	04:00 PM to 05:00 PM
B	Programme	Timing
1	<b>Poster Competition</b> <b>(White Color – A0/ A1 Chart Paper)</b>	
	<u><b>Topic for Employees , Children and Associates:</b></u> <b>“Beat Plastic Pollution to Restore Ecosystem”.</b>	<b>Prepare at home &amp; Submit to EHS Dept. by 3<sup>rd</sup> June 2023 (2.30 PM)</b>
C	Programme	Timing
1	<u><b>Environment Quiz Competition and Environment Awareness Programme for Children</b></u>	<b>04:30 PM to 05:30 PM</b> <b>at Township Club on</b> <b>04.06.2023 (Sunday)</b>







# Tree Plantation (CHP Area)

RELIANCE



# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12750

Annexure - 04

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Ambient Air Monitoring	Qty of Sample	:	30 ml
Lab. Ref. No.	:	AERL/300324A0005	Sample Bottle	:	Plastic packing & Filter paper
Dispatch No.	:	0020	Sample Location	:	Chaudhera
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

S. No.	Parameters	Unit	04.03.20 24	08.03.20 24	11.03.20 24	15.03.20 24	18.03.20 24	22.03.2 024	27.03.2 024	29.03.20 24	Standards
1.	Particulate matter (less than 10 µm)	µg/m <sup>3</sup>	70.59	76.98	70.89	74.69	72.86	74.89	75.34	75.16	100/Day
2.	Particulate matter (less than 2.5 µm)	µg/m <sup>3</sup>	30.24	34.28	28.69	32.59	32.89	34.00	32.15	35.12	60/Day
3.	Sulphur Dioxide (SO <sub>2</sub> )	µg/m <sup>3</sup>	24.59	27.49	20.36	27.59	24.79	28.67	25.64	25.07	80/Day
4.	Nitrogen Dioxide (NO <sub>2</sub> )	µg/m <sup>3</sup>	10.89	15.21	11.31	9.00	17.34	14.26	10.59	11.38	80/Day
5.	Ozone (O <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	100/8*Hours
6.	Lead (Pb)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	1.0/Day
7.	Carbon Mono Oxide (CO)	mg/m <sup>3</sup>	0.034	0.029	0.024	0.026	0.031	0.032	0.028	0.024	02/8*Hours
8.	Ammonia (NH <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	400/Day
9.	Benzene (C <sub>6</sub> H <sub>6</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	05/Annual
10.	Benzo(a)Pyrene(BaP) Particulate Phase only	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	01/Annual
11.	Arsenic (As)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	06/Annual
12.	Nickel (Ni)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	20/Annual
13.	Mercury (Hg)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Not Specified

(Authorized Signatory)



# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12750

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Ambient Air Monitoring	Qty of Sample	:	30 ml
Lab. Ref. No.	:	AERL/300324A0006	Sample Bottle	:	Plastic packing & Filter paper
Dispatch No.	:	0020	Sample Location	:	Bilandapur
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

S. No.	Parameters	Unit	05.03.2024	09.03.2024	12.03.2024	16.03.2024	19.03.2024	23.03.2024	26.03.2024	30.03.2024	Standards
1.	Particulate matter (less than 10 µm)	µg/m <sup>3</sup>	75.89	73.58	70.28	71.08	75.00	73.25	74.00	76.24	100/Day
2.	Particulate matter (less than 2.5 µm)	µg/m <sup>3</sup>	30.59	28.69	30.59	27.69	34.56	26.87	30.89	36.25	60/Day
3.	Sulphur Dioxide (SO <sub>2</sub> )	µg/m <sup>3</sup>	24.56	18.79	20.13	19.68	27.58	18.67	27.12	29.31	80/Day
4.	Nitrogen Dioxide (NO <sub>2</sub> )	µg/m <sup>3</sup>	15.64	10.69	11.59	12.54	15.67	10.59	19.71	15.34	80/Day
5.	Ozone (O <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	100/8*Hours
6.	Lead (Pb)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	1.0/Day
7.	Carbon Mono Oxide (CO)	mg/m <sup>3</sup>	0.028	0.027	0.035	0.034	0.027	0.021	0.032	0.03	02/8*Hours
8.	Ammonia (NH <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	400/Day
9.	Benzene (C <sub>6</sub> H <sub>6</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	05/Annual
10.	Benzo(a)Pyrene(BaP) Particulate Phase only	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	01/Annual
11.	Arsenic (As)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	06/Annual
12.	Nickel (Ni)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	20/Annual
13.	Mercury (Hg)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Not Specified

(Authorized Signatory)

# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetri1center@gmail.com

Web: www.aetri.com



TC-12750

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Ambient Air Monitoring	Qty of Sample	:	30 ml
Lab. Ref. No.	:	AERL/300324A0007	Sample Bottle	:	Plastic packing & Filter paper
Dispatch No.	:	0020	Sample Location	:	Behti
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

S. No.	Parameters	Unit	04.03.2024	08.03.2024	11.03.2024	15.03.2024	18.03.2024	22.03.2024	27.03.2024	29.03.2024	Standards
1.	Particulate matter (less than 10 µm)	µg/m <sup>3</sup>	74.89	77.48	75.21	75.89	74.69	77.68	72.69	76.01	100/Day
2.	Particulate matter (less than 2.5 µm)	µg/m <sup>3</sup>	31.26	30.69	24.81	34.81	34.18	35.16	30.69	30.71	60/Day
3.	Sulphur Dioxide (SO <sub>2</sub> )	µg/m <sup>3</sup>	28.34	26.41	18.47	28.14	28.46	31.56	22.98	29.34	80/Day
4.	Nitrogen Dioxide (NO <sub>2</sub> )	µg/m <sup>3</sup>	13.47	16.81	9.00	14.21	15.31	18.37	9.46	14.81	80/Day
5.	Ozone (O <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	100/8*Hours
6.	Lead (Pb)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	1.0/Day
7.	Carbon Mono Oxide (CO)	mg/m <sup>3</sup>	0.029	0.03	0.034	0.022	0.029	0.025	0.031	0.022	02/8*Hours
8.	Ammonia (NH <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	400/Day
9.	Benzene (C <sub>6</sub> H <sub>6</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	05/Annual
10.	Benzo(a)Pyrene(BaP) Particulate Phase only	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	01/Annual
11.	Arsenic (As)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	06/Annual
12.	Nickel (Ni)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	20/Annual
13.	Mercury (Hg)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Not Specified

(Authorized Signatory)

# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12750

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Ambient Air Monitoring	Qty of Sample	:	30 ml
Lab. Ref. No.	:	AERL/300324A0008	Sample Bottle	:	Plastic packing & Filter paper
Dispatch No.	:	0020	Sample Location	:	Barakatpur
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

S. No.	Parameters	Unit	05.03.2024	09.03.2024	12.03.2024	16.03.2024	19.03.2024	23.03.2024	26.03.2024	30.03.2024	Standards
1.	Particulate matter (less than 10 µm)	µg/m <sup>3</sup>	76.84	71.59	72.36	72.94	78.47	73.89	74.38	74.89	100/Day
2.	Particulate matter (less than 2.5 µm)	µg/m <sup>3</sup>	33.14	32.58	28.67	30.58	36.57	27.69	34.25	34.57	60/Day
3.	Sulphur Dioxide (SO <sub>2</sub> )	µg/m <sup>3</sup>	20.89	21.51	22.19	22.46	29.41	19.34	26.41	27.16	80/Day
4.	Nitrogen Dioxide (NO <sub>2</sub> )	µg/m <sup>3</sup>	10.89	14.87	14.21	19.46	18.71	12.47	12.46	18.00	80/Day
5.	Ozone (O <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	100/8*Hours
6.	Lead (Pb)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	1.0/Day
7.	Carbon Mono Oxide (CO)	mg/m <sup>3</sup>	0.026	0.028	0.034	0.035	0.029	0.025	0.032	0.033	02/8*Hours
8.	Ammonia (NH <sub>3</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	400/Day
9.	Benzene (C <sub>6</sub> H <sub>6</sub> )	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	05/Annual
10.	Benzo(a)Pyrene(BaP) Particulate Phase only	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	01/Annual
11.	Arsenic (As)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	06/Annual
12.	Nickel (Ni)	ng/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	20/Annual
13.	Mercury (Hg)	µg/m <sup>3</sup>	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Nil	Not Specified

(Authorized Signatory)

# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12780

Annexure - 05

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Noise Monitoring	Qty of Sample	:	NA
Lab. Ref. No.	:	AERL/300324N0001	Sample Bottle	:	NA
Dispatch No.	:	0020	Sample Location	:	Coal handling Plant
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

Date	DAY			NIGHT		
	L Min	L Max	Leq	L Min	L Max	Leq
06.03.2024	61.80	69.40	66.90	60.80	67.20	64.05
13.03.2024	62.40	69.20	65.71	59.00	65.90	63.33
20.03.2024	63.80	69.20	66.92	58.90	65.40	63.27
27.03.2024	59.00	69.40	65.26	63.70	63.70	61.30
MONTHLY AVERAGE	61.75	69.30	66.20	60.60	65.55	62.99
MIN Leq			65.26	MIN Leq		61.30
MAX Leq			66.92	MAX Leq		64.50

(Authorized Signatory)



# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com, aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12780

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Noise Monitoring	Qty of Sample	:	NA
Lab. Ref. No.	:	AERL/300324N0002	Sample Bottle	:	NA
Dispatch No.	:	0020	Sample Location	:	Permanent Store
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

Date	DAY			NIGHT		
	L Min	L Max	Leq	L Min	L Max	Leq
07.03.2024	59.00	66.10	62.61	58.10	64.20	61.36
14.03.2024	59.90	68.00	64.16	58.20	62.50	60.27
21.03.2024	59.90	66.80	63.66	60.30	68.40	64.88
28.03.2024	57.00	65.30	61.78	56.80	63.80	60.30
MONTHLY AVERAGE	58.95	66.55	63.05	58.35	64.73	61.70
MIN Leq			61.78	MIN Leq		60.27
MAX Leq			64.16	MAX Leq		64.88

(Authorized Signatory)



# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12780

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Noise Monitoring	Qty of Sample	:	NA
Lab. Ref. No.	:	AERL/300324N0003	Sample Bottle	:	NA
Dispatch No.	:	0020	Sample Location	:	1 meter from D.G. Area
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

Date	DAY			NIGHT		
	L Min	L Max	Leq	L Min	L Max	Leq
06.03.2024	64.20	70.20	67.06	52.30	56.10	54.77
13.03.2024	62.30	66.50	64.19	50.20	56.30	54.01
20.03.2024	64.50	68.90	66.93	50.40	54.20	52.14
27.03.2024	64.50	69.20	66.97	54.30	56.30	55.44
MONTHLY AVERAGE	63.88	68.70	66.29	51.80	55.73	54.09
MIN Leq			64.19	MIN Leq		52.14
MAX Leq			67.06	MAX Leq		55.44

(Authorized Signatory)

# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com, aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12750

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	As per Schedule
Nature of Sample	:	Noise Monitoring	Qty of Sample	:	NA
Lab. Ref. No.	:	AERL/300324N0004	Sample Bottle	:	NA
Dispatch No.	:	0020	Sample Location	:	Chaudhera
Sample Collected by	:	Sampling Staff		:	

## TEST RESULT

Date	DAY			NIGHT		
	L Min	L Max	Leq	L Min	L Max	Leq
07.03.2024	51.20	55.40	53.30	44.90	54.10	49.90
14.03.2024	51.60	55.90	53.77	43.90	57.30	52.58
21.03.2024	51.80	56.50	53.99	50.80	59.20	54.34
28.03.2024	53.20	56.30	54.98	49.60	59.40	56.07
MONTHLY AVERAGE	51.95	56.03	54.01	47.30	57.50	53.22
MIN Leq			53.30	MIN Leq		49.90
MAX Leq			54.98	MAX Leq		56.07

(Authorized Signatory)

# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



Annexure - 06

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	31/03/2024
Nature of Sample	:	Sewage Water Sample	Qty of Sample	:	1.0Ltr
Lab. Ref. No.	:	AERL/300324WW0003	Sample Bottle	:	1 Ltr Jerry can
Dispatch No.	:	0020	Sample Description	:	Outlet Sample STP Town Ship
Sample Collected by	:	Sampling Staff	D/o Sample Taken	:	30/03/2024
D/o Sample Analysis	:	31/03/2024	D/o of Completion Analysis	:	05/04/2024

## TEST RESULT

S. No.	PARAMETER	UNIT	PROTOCOL	RESULTS	Standard (CPCB) (max)	
					Inlands Surface Water	Public Sewer
1.	pH	.....	APHA 4500 H+B	7.74	6.5 - 8.5	6.5 - 8.5
2.	Total Suspended Solids(TSS)	Mg/l	APHA 4500 H+B	40	100	600
3.	Bio-Chemical Oxygen Demand (3days at 27°C)(BOD)	Mg/l	APHA 4500 (D)	6.0	30	350
4.	Chemical Oxygen Demand (COD)	Mg/l	APHA 4500 (B)	46	250	NS
5.	Oil & Grease (O&G)	Mg/l	APHA 4500 (B)	BDL	10	20
6.	Total Coliform	MPN/100 ml	IS 15185-2016 RA 2019	28	-	-
7.	Feecal Coliform	MPN/100 ml	IS 15185-2016 RA 2019	Absent	1000	-

(Authorized Signatory)

# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com, aetri2016@gmail.com, aetricenter@gmail.com

Web: www.aetri.com



TC-12780

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	31/03/2024
Nature of Sample	:	Sewage Water Sample	Qty of Sample	:	1.0Ltr
Lab. Ref. No.	:	AERL/300324WW0005	Sample Bottle	:	1 Ltr Jerry can
Dispatch No.	:	0020	Sample Description	:	Outlet Sample STP Plant Site
Sample Collected by	:	Sampling Staff	D/o Sample Taken	:	30/03/2024
D/o Sample Analysis	:	31/03/2024	D/o of Completion Analysis	:	05/04/2024

## TEST RESULT

S. No.	PARAMETER	UNIT	PROTOCOL	RESULTS	Standard (CPCB) (max)	
					Inlands Surface Water	Public Sewer
1.	pH	.....	APHA 4500 H+B	7.58	6.5 - 8.5	6.5 - 8.5
2.	Total Suspended Solids(TSS)	Mg/l	APHA 4500 H+B	44.0	100	600
3.	Bio-Chemical Oxygen Demand (3days at 27°C)(BOD)	Mg/l	APHA 4500 (D)	8.0	30	350
4.	Chemical Oxygen Demand (COD)	Mg/l	APHA 4500 (B)	40.0	250	NS
5.	Oil & Grease (O&G)	Mg/l	APHA 4500 (B)	BDL	10	20
6.	Total Coliform	MPN/100 ml	IS 15185-2016 RA 2019	18	-	-
7.	Feacal Coliform	MPN/100 ml	IS 15185-2016 RA 2019	Absent	1000	-

(Authorized Signatory)



# Advanced Environmental Testing And Research Lab P. Ltd.



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aetlgwalior@gmail.com, aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



TC-12780

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05/04/2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	31/03/2024
Nature of Sample	:	Sewage Water Sample	Qty of Sample	:	1.0Ltr
Lab. Ref. No.	:	AERL/300324WW0007	Sample Bottle	:	1 Ltr Jerry can
Dispatch No.	:	0020	Sample Description	:	Outlet Sample STP CHP Site
Sample Collected by	:	Sampling Staff	D/o Sample Taken	:	30/03/2024
D/o Sample Analysis	:	31/03/2024	D/o of Completion Analysis	:	05/04/2024

## TEST RESULT

S. No.	PARAMETER	UNIT	PROTOCOL	RESULTS	Standard (CPCB) (max)	
					Inlands Surface Water	Public Sewer
1.	pH	.....	APHA 4500 H+B	7.66	6.5 - 8.5	6.5 - 8.5
2.	Total Suspended Solids(TSS)	Mg/l	APHA 4500 H+B	48.0	100	600
3.	Bio-Chemical Oxygen Demand (3days at 27°C)(BOD)	Mg/l	APHA 4500 (D)	5.0	30	350
4.	Chemical Oxygen Demand (COD)	Mg/l	APHA 4500 (B)	42.0	250	NS
5.	Oil & Grease (O&G)	Mg/l	APHA 4500 (B)	BDL	10	20
6.	Total Coliform	MPN/100 ml	IS 15185-2016 RA 2019	24	-	-
7.	Feacal Coliform	MPN/100 ml	IS 15185-2016 RA 2019	Absent	1000	-

(Authorized Signatory)

# **ENVIRONMENTAL STATEMENT**

**OF**

**Rosa Power Supply Company Ltd.  
Shahjahanpur (U.P.)**

**2 x 300 MW (Stage-II)**

**FINANCIAL YEAR ENDING THE 31<sup>st</sup> MARCH, 2024**

**Prepared by:**

**Rosa Power Supply Company Ltd.  
Shahjahanpur (U.P.)**



(FORM – V)  
(See Rule 14)

Environmental Statement Report for the Financial Year ending the 31<sup>st</sup> March, 2024.

**PART – A**

(i) Name and address of the : Mr. H S Tomar  
Owner/occupier of the Industry Rosa Power Supply Co. Ltd.  
operation or process

Rausar Kothi

Hardoi Road

Distt. – Shajahanpur(U.P.)

(ii) Production Capacity : 2X300 MW

(iii) Year of Establishment : Jan 2012

(iv) Date of Last environmental statement : 06.05.2023  
submitted

(v) Industry category : Thermal Power Plant

Primary : (STC Code)

Secondary : (SIC Code)



**PART – B**

**(Water and Raw Material Consumption)**

**1. Water Drawn M<sup>3</sup>/Day**

(All values indicate Annual consumption)

			<b>FY 2022-23</b>	<b>FY 2023-24</b>	<b>Remarks</b>
(i)	Gross Energy Generation (MU)	:	3601.81	3685.30	Unit Generation is more than previous year.
(ii)	Water consumption	:	5360413 M <sup>3</sup>	4968617 M <sup>3</sup>	Total Water Consumption is more due to more generation than previous year.
(iii)	Process	:	1157849 M <sup>3</sup>	1073221 M <sup>3</sup>	-do-
(iv)	Condenser Cooling	:	4187018 M <sup>3</sup>	3880987 M <sup>3</sup>	-do-
(v)	Domestic	:	15545 M <sup>3</sup>	14409 M <sup>3</sup>	-do-

<b>S.No.</b>	<b>Name of the product</b>	<b>Process water Consumption per unit of product output.</b>	
		<b>FY 2022-23</b>	<b>FY 2023-24</b>
1	Electricity	<b>0.32 Ltr/Unit*</b>	<b>0.29 Ltr/Unit*</b>

*\*The specific process water consumption was less due to efficient Operation.*

**2. Raw Material Consumption**

<b>Name of Raw Material</b>	<b>Name of the product</b>	<b>Consumption of Raw Material unit of output</b>			
		<b>FY 2022-23</b>		<b>FY 2023-24</b>	
Coal	Electricity	Total Consumption(MT):	2230207	Total Consumption(MT)	2286189
		Specific Consumption per kw:	0.62Kg/Unit*	Specific Consumption per kw	0.62Kg/Unit*

*\*Sp. Coal consumption was almost same compared to the previous year due to efficient operation.*





## PART – C

### Pollution discharged to Environment/Unit of output

(Parameter as specified in the consent issued)

Pollutants	Quantity of Pollutions discharged (mass/day)	Concentration of Pollutants in discharge (mass/volume)	Percentage of variation from prescribed Standards												
<b>Water Treated Effluent Discharge*</b>  <table><tr><th>Unit</th><th>Limit</th></tr><tr><td>pH</td><td>5.5. to 9.0</td></tr><tr><td>SS</td><td>&lt; 100 mg/l</td></tr><tr><td>Oil &amp; Grease</td><td>&lt; 10 mg/l</td></tr><tr><td>BOD<sub>5</sub></td><td>&lt; 30 mg/l</td></tr><tr><td>COD</td><td>&lt; 250 mg/l</td></tr></table>	Unit	Limit	pH	5.5. to 9.0	SS	< 100 mg/l	Oil & Grease	< 10 mg/l	BOD <sub>5</sub>	< 30 mg/l	COD	< 250 mg/l	The Effluent Treatment facility for Stage I and II is common. Please refer Env Statement of Stage I.		
Unit	Limit														
pH	5.5. to 9.0														
SS	< 100 mg/l														
Oil & Grease	< 10 mg/l														
BOD <sub>5</sub>	< 30 mg/l														
COD	< 250 mg/l														
<b>Air**</b>  SPM-Unit 3 SPM-Unit 4	1787.45 1928.04 kg/day	46.08 48.63 mg/Nm <sup>3</sup>	-												

\* Report Enclosed as Annexure 1 of Stage\_1

\*\* - As per Test Report of MoEF approved Laboratory dated 21.03.2024 of Unit 3 & dated 28.03.2024 of Unit 4 of Stage-2 respectively (Enclosed as **Annexure 2**).



PART – D

HAZARDOUS WASTES

(As specified under Hazardous wastes/management  
& Handling Rules, 1989)

Hazardous Wastes	Total Qty (KG)	
	FY 2022-23	FY 2023-24
(a) From Process	10.07 KL(Spent Oil) 164.00 kg (Waste containing oil)	36.22 KL(Spent Oil) 4445.78 kg (Waste containing oil)
(b) From Pollution Control facilities	2.01 KL (Apportioned in the ratio of generation)	7.24 KL (Apportioned in the ratio of generation)

The RPSCL has obtained Hazardous Waste Authorization from UPPCB for Collection & Storage of Hazardous waste.

- RPSCL has obtained renewed Hazardous Waste Authorization from UPPCB for Collection & Storage of Hazardous waste in 2023-24.
- Waste / Spent Oil is collected at centrally located point in isolated storage area meant for them in sealed Drums, which is further sent to authorized recycler for disposal as per norms of MoEF.



PART – E

SOLID WASTES

Total Quantity

Solid Wastes:

Solid Wastes:	Total Qty (Metric tonne or MT)	
	FY 2022-23	FY 2023-24
(i) From Process	163391 MT (Bottom Ash)	164813 MT (Bottom Ash)
(ii) From Pollution Control Facilities		
• Ash	653565 MT (Fly Ash)	659253 MT (Fly Ash)
c)	Ash in MT	Ash in MT
I. Quantity recycled or re-utilized within unit	I. 186	IV. 30035
II. Sold*	II. 500792	V. 0
III. Disposed	III. 252920	VI. 0

❖ \*The ash is given to various agencies free of cost.



## PART – F

### Indicate disposal practice adopted for Hazardous as well as solid waste

- a) **Coal Ash:** As per MoEF guidelines, ash is being given to outside brick unit other than brick kiln, various cement industries for using ash as ingredients in their cement manufacturing units from our silo in closed trucks. Pond ash is lifted for Ash Pond dyke bund rising.
- b) **Used Batteries:** Collected centrally at store in isolated place for disposal to authorized agencies as per MoEF guidelines.
- c) **Hazardous waste:** Waste oil, Oil soaked cotton is collected in store for disposal to authorized agencies as per latest guidelines of MoEF.
- d) **E-Waste-** E-Waste is collected in store for disposal to authorized agencies as per latest guideline of MoEF.
- e) **Bio-Medical Waste-** Bio-medical waste is picked up by authorized agencies on daily basis from health centre.



## PART – G

*Impact of the pollution control measures taken on conservation of natural Resources and consequently on the cost of production.*

Pollution Control facilities such as ETP/ STP help in conservation of water resources. The treated water from ETP & STP is used for Ash Handling & Horticulture. Also, the plant is operated on a CoC of more than 5 as against the designed CoC of more than 4 which is helping in further water conservation. All these measures effectively reduce the fresh water intake.



## PART – H

### **Additional investment proposal for environmental protection abatement of pollution, prevention of pollution**

1. Tree Plantation is being carried out in and around the plant premises. Total 16550 nos. of trees and shrubs have been planted in the FY 2023-24 (common for stage 1 & 2). Total 601752 trees has been planted so far in area of 283 Ha i.e approx 46% against 33% greenbelt of MoEF Guideline.
2. During Financial year 2023-24 total expenditure of Rs 1.5 Cr approximately done on horticulture & greenery development (common for stage 1 & 2).
3. Company has successfully passed the surveillance Audit for the Environment Management System Certification (ISO 14001:2015).
4. Continuous Air Quality Monitoring Stations (CAAQMS) have been installed in FY 2013-14, Continuous Effluent Monitoring System (CEMS) have been installed in FY 2014-15, and Connected data of Stack Emission, Effluent with CPCB Server in FY 2015-16, Online Coal Ash Analyser in FY 2017-18, Remote Calibration Facility in FY 2019-20 of CEMS, Modification of STP CHP in FY 2020-21, Modification of STP Switchyard (Plant site) in FY 2023-24 with an approximate investment of Rs 1.5 crore, 13 Lacs, 5 Lacs, 34 Lacs, 23.50 Lacs and 18 Lacs approximately respectively. One CAAQMS station with online weather station has been upgraded with E series costing approx 45 lacs.



## PART – I

### Any other particulars for improving the quality of environment.

- (1) We are complying with all the directions and conditions of state and central pollution boards and regular Water & Air consents are in force.
- (2) Regular monitoring of Noise level, AAQ, Waste and Stack Gases is being done. Waste water treatment and recycling is in practice.
- (3) Almost 16550 Tree and shrubs Plantation has been done in the year 2023-24 for improving the quality of environment (commonly for Stage 1 & 2).
- (4) Water conservation by Ash water recirculation.
- (5) To further improve the treated water quality at plant STP, Dual Media Filter has been provided.
- (6) Tree plantation, Prabhat Pheri and Quiz programmes organized on World Environment Day-2023 to increase environmental awareness among employees (Refer **Annexure\_3 of Stage\_1**)
- (7) Training to employees from different departments has been given on Environmental Management System (ISO 14001:2015) and environmental aspect impact assessment
- (8) Good Practices/ Environmental Improvement Plans were made to achieve continual Improvement of Environment.

Note: Environmental Monitoring reports AAQ, Noise, STP, and ETP are enclosed as (Refer Annexure 4, 5, 6 & Annexure 1 of Stage 1)

#### Following Environmental Improvement Plans were done during the FY 2023-24

- (1) Waste Disposal - Different color coding of drums for Oily waste and General Waste, Segregation of E-waste, Electrical waste
- (2) PCC of the oil storage shed at maintenance yard of all contractors' area
- (3) Agreement for Biomedical waste disposal with approved agency and renewal of Bio Medical Waste Authorization
- (4) Remote Calibration facility with CPCB server upgraded for online Stack Emission Data as per CPCB Guideline.
- (5) Re-utilising the treated effluent from Coal Settling Pit for dust suppression in CHP Area
- (6) Interconnecting sewage water of admin building and fire station with STP for optimum utilization of Sewage Treatment Plant. Also new STP of 20 KLD installed at CHP area to treat sewage water.





# Advanced Environmental Testing And Research Lab P. Ltd.

CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aelgwalior@gmail.com aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



TC-12750

Annexure - 02

## TEST REPORT

Company Name	: Rosa Power Supply Co. Ltd.	Date of Issue	: 05.04.2024
Address	: Rosa, Shahjahanpur, UP, India	Date of Sample Received	: 01.03.2024 to 31.03.2024
Location	: Stack Monitoring	Monitoring Conducted by	: Sampling Staff
Source of Monitoring	: Boiler Stack -3 (Bi-Flue) of Stage - 2	Environmental Conditions during Sampling	: Sunny
Lab. Ref. No.	:	Material of Construction	: MS
Dispatch No.	:	Height From Ground Level	: 65 M

Stack Area / Shape	Boiler Stack - 3
Capacity	05M/ Circular
Type of Fuel Used/Consumption per day	1025 TPH
Thimble No.	Coal/ 190tph
Stack Height (M)	March-03, March-07, March-11, March-15
	275

## TEST RESULT

S.No	Parameter	Unit	Monitoring Date				Protocol/Method Followed
			07.03.2024	14.03.2024	21.03.2024	28.03.2024	
1.	Temperature	°C	127.00	129.00	128.00	132.00	
2.	Velocity	m/s	29.63	30.30	31.03	31.44	
3.	Sulphur dioxides (SO <sub>2</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	1114.67	1120.00	1160.00	1176.00	IS:11255(Pt-2)2005 (Reaffirmed – 2009)
	Sulphur dioxides (SO <sub>2</sub> ) with 6% O <sub>2</sub> correction		1016.10	913.54	1076.73	934.82	
4.	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	316.40	323.28	357.67	337.03	IS:11255(Pt-2)2005 (Reaffirmed – 2012)
	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) with 6% O <sub>2</sub> correction		288.42	263.69	332.00	267.91	
5.	Particulate matter (PM)	(mg/Nm <sup>3</sup> )	48.17	47.60	46.08	46.86	IS:11255(Pt-I)1985 (Reaffirmed – 2003)

  
Authorized Signatory





CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎ 0751-3566867, 2232177

Email: aetgwalior@gmail.com aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



TC-12750

Annexure- 02

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05.04.2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	01.03.2024 to 31.03.2024
Location	:	Stack Monitoring	Monitoring Conducted by	:	Sampling Staff
Source of Monitoring	:	Boiler Stack -3 (Bi-Flue) of Stage - 2	Environmental Conditions during Sampling	:	Sunny
Lab. Ref. No.	:		Material of Construction	:	MS
Dispatch No.	:		Height From Ground Level	:	65 M

	<b>Boiler Stack - 3</b>
Stack Area / Shape	05M/ Circular
Capacity	1025 TPH
Type of Fuel Used/Consumption per day	Coal/ 190tph
Thimble No.	March-03, March-07, March-11, March-15
Stack Height (M)	275

## TEST RESULT

S.No	Parameter	Unit	Monitoring Date				Protocol/Method Followed
			07.03.2024	14.03.2024	21.03.2024	28.03.2024	
1.	Temperature	°C	127.00	129.00	128.00	132.00	
2.	Velocity	m/s	29.63	30.30	31.03	31.44	
3.	Sulphur dioxides (SO <sub>2</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	1114.67	1120.00	1160.00	1176.00	IS:11255(Pt-2)2005 (Reaffirmed – 2009)
	Sulphur dioxides (SO <sub>2</sub> ) with 6% O <sub>2</sub> correction		1016.10	913.54	1076.73	934.82	
4.	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	316.40	323.28	357.67	337.03	IS:11255(Pt-2)2005 (Reaffirmed – 2012)
	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) with 6% O <sub>2</sub> correction		288.42	263.69	332.00	267.91	
5.	Particulate matter (PM)	(mg/Nm <sup>3</sup> )	48.17	47.60	46.08	46.86	IS:11255(Pt-I)1985 (Reaffirmed – 2003)

Authorized Signatory



CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories

Approved: by Ministry of Environment, Forest and Climate Change (MoEF&CC)

Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aetgwalior@gmail.com aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



TC-12780

## TEST REPORT

Company Name	:	Rosa Power Supply Co. Ltd.	Date of Issue	:	05.04.2024
Address	:	Rosa, Shahjahanpur, UP, India	Date of Sample Received	:	01.03.2024 to 31.03.2024
Location	:	Stack Monitoring	Monitoring Conducted by	:	Sampling Staff
Source of Monitoring	:	Boiler Stack -4 (Bi-Flue) of Stage - 2	Environmental Conditions during Sampling	:	Sunny
Lab. Ref. No.	:		Material of Construction	:	MS
Dispatch No.	:		Height From Ground Level	:	65 M

	<b>Boiler Stack - 4</b>
Stack Area / Shape	05M/ Circular
Capacity	1025 TPH
Type of Fuel Used/Consumption per day	Coal/ 190tph
Thimble No.	March-04, March-08 March-12 March-16
Stack Height (M)	275

## TEST RESULT

S.No.	Parameter	Unit	Monitoring Date				Protocol/Method Followed
			07.03.2024	14.03.2024	21.03.2024	28.03.2024	
1.	Temperature	<sup>0</sup> C	129.00	130.00	126.00	131.00	
2.	Velocity	m/s	30.89	30.54	29.06	31.95	
3.	Sulphur dioxides (SO <sub>2</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	1109.33	1141.33	1157.33	1152.00	IS:11255(Pt-2)2005 (Reaffirmed – 2009)
	Sulphur dioxides (SO <sub>2</sub> ) with 6% O <sub>2</sub> correction		1122.43	1053.21	1170.60	1019.17	
4.	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) without O <sub>2</sub> correction	(mg/Nm <sup>3</sup> )	330.16	309.52	364.55	371.43	IS:11255(Pt-2)2005 (Reaffirmed – 2012)
	Oxides of Nitrogen NO-NO <sub>2</sub> (NO <sub>x</sub> ) with 6% O <sub>2</sub> correction		334.05	285.62	368.73	328.60	
5.	Particulate matter (PM)	(mg/Nm <sup>3</sup> )	46.07	46.10	47.75	48.63	IS:11255(Pt-1)1985 (Reaffirmed – 2003)

Authorized Signatory